FusionPartitions

Acoustic Performance

to BS EN ISO 10140-2: 2010

Document No. CDG-AP4

Frequency Partitioning System

Double Glazed Screen with Mullion

This is to advise that the double glazed construction combination of the above partitioning system has been assessed for acoustic performance based on the published performance information on tests that were carried out in accordance with BS EN ISO 10140-2 and resulting Rw performance being derived from BS EN ISO 717/1.

10mm Toughened Safety Glass
and
12.8mm Acoustic Laminated Safety Glass

R_W 48dB

Unit 6 : I O Centre : Salbrook Road Industrial Estate : Salfords : Surrey : RH1 5GJ
Tel 01293 220970 E-mail info@fusionpartitions.com